4658845811

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Randy Buie DATE 4-30-86 PERMIT NO. 228

PHONE: Business _____ Home _____

LOCATION 115 N TR in Collins Park 2nd house on Rt.

S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other Repair

No. Bedrooms _____ No. Bathrooms _____
Garbage Disposal Unit Yes ( ) No ( )
Auto. Dishwasher Yes ( ) No ( )
Auto. Wash. Machine Yes ( ) No ( )
Site Suitable Yes ( ) No ( )

Character & Porosity of Soil Clayey
Percolation Rate 1.3
Topography 2 to 6 %
Depth to Water Table 10'+
Rock or other impervious formations none

Lot Area _____

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System

Size of Tank Existing Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 744 Linear Ft. 248
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by Benton Landscaping Inc.

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

lay-out amended 4-18-86 fcm

IMPROVEMENTS PERMIT BY L. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY L. C. Moore DATE 4-30-86

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Randy Bire DATE 5-1-83 PERMIT NO. [illegible]

PHONE: Business _____ Home _____

LOCATION 115 N TR 2500 XRR 2nd house on R

S. R. No. _____


SUBDIVISION NAME Collins Park LOT NO. _____ SECTION OR BLOCK NO. _____

House (X) Mobile Home ( ) Business ( ) Other Repair

No. Bedrooms 3 No. Bathrooms 2

~~Garbage Disposal Unit~~	~~Yes~~ ( )	No (X)	Character & Porosity of Soil		
Auto. Dishwasher	Yes (X)	No ( )	Percolation Rate		
Auto. Wash. Machine	Yes (X)	No ( )	Topography	EXISTING	
Site Suitable	Yes (X)	No ( )	Depth to Water Table	System	
Lot Area EXISTING			Rock or other impervious formations		

( ) Basement with Plumbing ( ) Basement without Plumbing (X) No Basement



Plot of System

Size of Tank _____ Gals.

Nitrification Field: 180 Linear FT

No. of Lines 2 Row Panels

Sq. Ft. _____ Linear Ft. ~~16" Panels~~

Depth of Stone in Lines _____

Water Supply: Individual (X)

Public ( )

USE 1FT Filter SAND

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed X Tina Bire

→ At owners request changed to conventional line all that we can get in. Perm

IMPROVEMENTS PERMIT BY Fred Clemmer

COMMENTS: Keep panels as shallow as possible, install french drain to prevent lateral H2O movement

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold