4658851241

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Hayden Goins DATE 7-13-79 PERMIT NO. 240

PHONE: Business _____ Home _____


LOCATION 115 N Tr on 2500 Tr on 2501
Last house on left S. R. No. _____

SUBDIVISION NAME Collins Park LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other Repair

No. Bedrooms 3 No. Bathrooms 2
Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area ~½ ac.

Character & Porosity of Soil Clay loam
Percolation Rate 30 mpi
Topography 6-8%
Depth to Water Table sink.
Rock or other impervious formations none obs.



Plot of System

Size of Tank Existing Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 450 Linear Ft. 150
Depth of Stone in Lines 16"+
Water Supply: Individual (✓)
Public ( )

Installed by Ronald Jackey

IMPROVEMENTS PERMIT BY R K Hinson

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Ronald K. Hinson DATE 7-13-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold