IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Scott Seay DATE 4-16-80 PERMIT NO. 81

PHONE: Business _____ Home _____

LOCATION 115 N TR 2406 Bear Rt on 2500 TL 2501 1st house on left

_____ S. R. No. _____


SUBDIVISION NAME Collins Park LOT NO. 7 SECTION OR BLOCK NO. _____

House (X) Mobile Home ( ) Business ( ) Other Repair - Adding Washer System

No. Bedrooms 3 No. Bathrooms 1-2

Garbage Disposal Unit	Yes ( )	No ( )	Character & Porosity of Soil _____
Auto. Dishwasher	Yes ( )	No ( )	Percolation Rate _____
Auto. Wash. Machine	Yes ( )	No ( )	Topography _____
Site Suitable	Yes ( )	No ( )	Depth to Water Table _____
			Rock or other impervious formations _____

Lot Area _____



Plot of System

Size of Tank [redacted] 500 gallons Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 300 Linear Ft. 100
Depth of Stone in Lines 16"
Water Supply: Individual (X)
Public ( )

Installed by Ross Perkins

IMPROVEMENTS PERMIT BY David R. Henson

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Fred Clemmer DATE 4-16-80

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold