IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR R A. Smith Builders DATE 6-23-80 PERMIT NO. 179

PHONE: Business / Home

LOCATION Hwy 115 N. TR 2406 BR 2500 TL 2501 2nd on Rt.

SUBDIVISION NAME Collins Park LOT NO. 2 S. R. No. SECTION OR BLOCK NO. B


House (X) Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (X)	Character & Porosity of Soil	Clay loam
Auto. Dishwasher	Yes (X)	No ( )	Percolation Rate	30 – 60 min per 2 – 6 in
Auto. Wash. Machine	Yes (X)	No ( )	Topography	
Site Suitable	Yes (X)	No ( )	Depth to Water Table	unknown
			Rock or other impervious formations	None observed

Lot Area 38,500 9'x84'

Basement with Plumbing ___ Basement without Plumbing ___ X No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 750 Linear Ft. 250
Depth of Stone in Lines 16"

Water Supply: Individual (X)
Public ( )

Installed by F. J. Ervin

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: ___

IMPROVEMENTS PERMIT BY Fred Clemmer

COMMENTS: Septic Tank 42' to Right Front Edge of front porch

CERTIFICATE OF COMPLETION BY Fred Clemmer DATE 6-24-80

EXISTING SYSTEM CHECKED BY: ___ DATE ___

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.
Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold