IREDELL COUNTY HEALTH DEPARTMENT 4658-85-5120

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Southern Constructors, Inc DATE 9-10-80 PERMIT NO. 284

PHONE: Business _____ Home _____

LOCATION 115 N, TR 2406 Bear Rt on 2500 Lot on corner of 2500 and 2501

SUBDIVISION NAME Collins Park S. R. No. _____


LOT NO. 3 SECTION OR BLOCK NO. B

House (X) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (X)	Character & Porosity of Soil	Clay loam
Auto. Dishwasher	Yes ( )	No (X)	Percolation Rate	30 min/in
Auto. Wash. Machine	Yes (X)	No ( )	Topography	Gently Rolling
Site Suitable	Yes (X)	No ( )	Depth to Water Table	Unknown
Lot Area 20,000 ft²			Rock or other impervious formations	None observed

_____ Basement with Plumbing _____ Basement without Plumbing X No Basement



Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines _____
Sq. Ft. 750 Linear Ft. 250
Depth of Stone in Lines 16"

Water Supply: Individual (X)
Public ( )

Installed by Richard Abernathy

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Fred Clemmer

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Fred Clemmer DATE 9-10-80

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.
Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold