(4:00)

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 073370 PIN# 4658849772 4658951294 DATE June 3, '98

OWNER OR CONTRACTOR Krom Financial PHONE: Business 664-3671 Home

ADDRESS 149 Yacht Cove Rd. Mooresville

LOCATION 115 N. TR Barclay TR new STREET AT END 162 Creek Branch Dr.

SUBDIVISION Collins Park BLOCK / SECTION II LOT 5 LOT AREA 1.66Ac SITE CLASS. RS DESIGN FLOW 360gpd L.T.A.R. .03

Septic Tank: 1000 Gallons; STB 825 Date 10/21/98

Pump Tank: 1000 Gallons; PT 47 Date 10/20/98

Pump Make: Hydromatic Model SP50 Serial No.

Nitrification Field: No Fields 1 Square Feet 1200 Linear Feet 400

No Lines 3 @ 133' Trench Width 36" Max Trench Bottom Depth 18-24" Gravel Depth 12"

☑ New System ☐ Repair System Type: I, II, (III) IV, V, VI

System Description: pumped-pm - conventional

Repair System Description: same

Maintenance Agreement Required: ☐ Yes ☑ No

☑ House/Mod. Home No. Bedrooms 3

☐ Mobile Home No. Bathrooms 2

☐ Business No. Employees

☐ Other

☐ Slab ☑ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Water Supply: ☑ Individual ☐ Public ☐ Community

Comments:/Conditions:

1" = 50'

132'

245-0477

Well

INITIAL SITE SKETCH

Ditch

Drained

Barclay

Well

296'

Rowan Area

Wet Weather Ditch

50' x 72' House

Pt 5K

Steep

Gully / Wet Weather Ditch

Schepm

348.75

AS BUILT SKETCH

Comments:/Conditions:

I understand that this permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid ~~without expiration~~. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: X date 6-18-98 Installed by: Rowan Septic Tank

Improvement Permit by: David R. Hamm RS date 6-3-98 Operation Permit by: Wesley Sparks RS. date 12/22/98

Authorization to Construct by: David R. Hamm RS date 6-18-98 Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE INSPECTION COPY (FINAL): GREEN OWNER COPY (FINAL): YELLOW INSPECTION COPY (INITIAL): PINK OWNER COPY (INITIAL): GOLD