ON-SITE WASTEWATER SECTION

COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Krom APPLICANT: _____

ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 5-12-98

PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____

LOCATION OF SITE: Lot 5 Collins Lake PROPERTY RECORDED: _____

WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____

EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut

TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN)	SOIL MORPHOLOGY (1941) 1941 STRUCTURE/ TEXTURE	1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS 1942 SOIL WETNESS/ COLOR	1943 SOIL DEPTH	1950 SAPRO CLASS	1944 RESTR. HORIZ.	PROFILE CLASS & LTAR
1	2 ridge	0-4	gr loam SL	fr					BS 34
		4-48	SAB red/gl	fr sl-sst SSP					
2		0-17	SAB pbrn	e fi sp					(LL)
		17-30	mk SAB gr sd	fr sp mw	10YR				
3		0-5	gr loam sl fri fi fr						BS 3 @ 52"
		5-16	SAB rd	fr sp	5YR				
		16-33	SAB gr cl	mang fe/mn mottles, few int stg					
		33-48	wksm/mk SAB gr cl	fi sss sp					
			mumerous f-few mottles, few matrix colors						
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): _____

SITE CLASSIFICATION (.1948): _____

EVALUATED BY: _____

OTHER(S) PRESENT: _____