4658974173

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Jerry E Josey, JR. DATE 6-22-84 PERMIT NO. 201

PHONE: Business _____ Home _____

LOCATION Hwy 115 N TR 2383 1/4 mile TR 1st private drive 2nd lot on left

S. R. No. _____

SUBDIVISION NAME former Whitley Meadows property LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (X) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (X)

Auto. Dishwasher Yes (X) No ( )

Auto. Wash. Machine Yes (X) No ( )

Site Suitable Yes (X) No ( )

Lot Area 2 ACRES


Character & Porosity of Soil Clay loam friable

Percolation Rate 0.5 gal/ft/day

Topography Slight 4%

Depth to Water Table 4FT

Rock or other impervious formations None obs.



Size of Tank 1500 Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 720 Linear Ft. 240
Depth of Stone in Lines 12"

Water Supply: Individual (X)
Public ( )

Installed by Wayne Ohlson

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Joel Clemmer + Charles Barnett

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Joel Clemmer DATE 6-22-84

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Jerry E. Josey Jr. DATE 5-25-84 PERMIT NO. 122

PHONE: Business _____ Home _____

LOCATION 21 & 115 N TR Shinnville Rd. 1st private Dr. on Rt 2nd Lot on Lt

S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (X) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (X)
Auto. Dishwasher	Yes (X)	No ( )
Auto. Wash. Machine	Yes (X)	No ( )
Site Suitable	Yes (X)	No ( )

Lot Area 2 acres Lot 1 INP


Character & Porosity of Soil Clay loam

Percolation Rate .5 gal / ft2 / day

Topography 2-6% slope

Depth to Water Table 4'

Rock or other impervious formations NONE



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 720 Linear Ft. 240
Depth of Stone in Lines 12"

Water Supply: Individual (X)
Public ( )

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: Jerry E Josey Jr

IMPROVEMENTS PERMIT BY Charles R. Barnett & Fred Clemmer

COMMENTS: Lot Line

Keep system shallow, follow contour of land

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold