VISION OF ENVIRONMENTAL HEALTH
N-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

WNER: _____ APPLICANT: _____
DDRESS: _____ APPLICATION DATE: 9/14/00 DATE EVALUATED: 10/24/00
ROPOSED FACILITY: 4BD MOD. PROPOSED DESIGN FLOW (.1949): 480 PROPERTY SIZE: .71
OCATION OF SITE: Lot 148 Wimmd Pointe Ph 3 PROPERTY RECORDED: _____
/ATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
VALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
YPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LAND-SCAPE POSITION/ SLOPE %	HORI-ZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	LS 3-4% Lot 148	0-2	O						.3
		2-17	SBK/cl	FR SS SP					
		18-28	mSBK/scl	FR SS NP					
		29-36	FGR/cl SAP	FR SS NP					.35
		37-48	FSG/l SAP	VFR SS NP					
2	4%	0-4	O						
		5-13	SBK/cl	VFI SS NP					
		14-30	SBK/hcl	FI SS SP					.3
		31-48	LARGE SSBK/cl	FI SS NP					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
vailable Space (.1945)		
/stem Type(s)		
te LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____