HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

PROPERTY I.D.#:
PROPERTY RECORDED:
COUNTY:

SOIL/SITE EVALUATION

FOR

ON-SITE WASTEWATER SYSTEM

APPLICANT: Pruett Mfg Co. OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED: 3/27/97
PROPOSED FACILITY:
PROPERTY SIZE:
LOCATION OF SITE: lot 20 Windward PT
WATER SUPPLY: On-Site Well Comm. Well Public Other EVAL. METHOD: Auger Boring Pit Cut

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	L ~25%	0-9	gr brn sl/scl fr						.45 .3
		9-14	gr rdsh brn scl fr						
		14-25	ssbk rc	fr sp so					
		25-48	msbk rcl	fr sp ss so/p					
			few mnl so/p, few mottles						
2	L ~5%	0-6	gr brn sl/scl fr						.45 .3
		6-15	ssbk brn, rdsh brn clay fm	fr so/p					
		15-26	ssbk rc	fr sp so					
		26-48	msbk rcl	fr sp ss so/p					
			few yellowish mottles, mnl fm so/p, common mica flakes						
3									
4									
5									

AVAILABLE SPACE (.1945): SITE CLASSIFICATION (.1948): SITE LONG-TERM ACCEPTANCE RATE:

EVALUATED BY: OTHER(S) PRESENT:

COMMENTS: