DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET ____ OF ____
PROPERTY I.D.#: ____
PROPERTY RECORDED: ____
COUNTY: ____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Keith Norris OWNER: __ AGENT: __ PHONE: ____
ADDRESS: ____ APPLICATION DATE: ____ DATE EVALUATED: 11-15-26
____ PROPOSED FACILITY: ____
____ PROPERTY SIZE: ____
LOCATION OF SITE: Lot 23 Woodcreek Est
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other ____ EVAL. METHOD: Auger Boring ___ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	L 5 REDUCED 0-10%	0-20"	SaSiL gr cr sbk	fr so so sp					R5 C3 22-30"
		20-35"	mottled sbk fr so so sp						
		35-48+	gr w/ fr so sp						
		Restrictive soil depth = 35" to 48"							
2	L 5 WPB 2 CREEK	0-17	SaSiL brn	fr so so sp					R5 C3
		17-48	mottled gr at 36"						
			SaSiL w/ sp						
3	L 15%	0-14"	SaSiL brn	fr so so sp					R5 C3 30-36"
		36-48	mottled SaSiL w/ sp	fr so sp					
4	L 15-20% 100 FEET	0-17	SaSiL brn	fr so so sp	15"+				42
		17-28	SaSiL w/ mottles						
		28-48	WPR/SaSiL w/ mottles						
5	L 15-20%	0-12"	SaSiL brn	fr so so sp					R5 C3 22-30"
		12-36	SaSiL mottled brn	fr so so sp					
		Restrictive depth = 36"							

AVAILABLE SPACE (.1945) ____ SITE CLASSIFICATION (.1948): ____ SITE LONG-TERM ACCEPTANCE RATE: ____

EVALUATED BY: ____ OTHER(S) PRESENT: ____

COMMENTS: ____

Very little usable space left. Some site constraints. Perc is adequate for 3 BR home. Use area under apple trees for repair area.