VISION OF ENVIRONMENTAL HEALTH
N-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

WNER: Pruitt Dev. Co. APPLICANT: _____
DDRESS: _____ APPLICATION DATE: 7/00 DATE EVALUATED: 9/16/00
ROPOSED FACILITY: 3BD - PROPOSED DESIGN FLOW (.1949): 360GPD PROPERTY SIZE: _____
OCATION OF SITE: Lot 181 Winward Pointe PROPERTY RECORDED: _____
'ATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
VALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
YPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LAND-SCAPE POSITION/ SLOPE %	HORI-ZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	CCL 6%	0-9	SC SBK / cl	FI SS SS					
		10-21	SM SBK / l	FI SS NP					
		22-48	SF GR / LSAP	VFR SS NP					
2									
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
vailable Space (.1945)	U	
ystem Type(s)		
te LTAR		

OTHER FACTORS (.1946): LOT TO SHALLOW FOR HOME
SITE CLASSIFICATION (.1948): 23' FROM REAR P/L
EVALUATED BY: [signature]
OTHER(S) PRESENT: _____