...MENT OF ENVIRONMENT, HEALTH AND NATURAL RESOURCES
...ISION OF ENVIRONMENTAL HEALTH
...WASTEWATER SECTION

PROPERTY ID #:
COUNTY:

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Pruett Dev. Co. APPLICANT:
ADDRESS: APPLICATION DATE: DATE EVALUATED: 2/27/97
PROPOSED FACILITY: PROPOSED DESIGN FLOW (.1949): PROPERTY SIZE: 120'x82'
LOCATION OF SITE: Lot 46 Windward Pt. PROPERTY RECORDED:
WATER SUPPLY: ☒ Private ☐ Public ☒ Well ☐ Spring ☐ Other
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN)	SOIL MORPHOLOGY (1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	OTHER PROFILE FACTORS .1943 SOIL DEPTH	OTHER PROFILE FACTORS .1956 SAPRO CLASS	OTHER PROFILE FACTORS .1944 RESTR HORIZ	PROFILE CLASS & LTAR
L 1-10%	0-3	gr Vfsl sl						PS >25-.3
	3-10	ssab R,						
	10-20	msab, RO						
	20-46	wkab e,vfr						
		w/ v-pr/blk matrix,						
L 8-10%	0-7	gr-sbk lvfsl-fsl						PS e25-.3
	7-36	sbk R C						
	36-48	mod/wkab bm,R						
		mot SAP/gr wk						

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Space (.1945)		
Type(s)		
LTAR		

OTHER FACTORS (.1946):
SITE CLASSIFICATION (.1948):

EVALUATED BY:
OTHER(S) PRESENT: