DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Quartet Homes Inc. APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 3/20/07
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): 3 bdrm PROPERTY SIZE: _____
LOCATION OF SITE: Lot 12 Woodland Est PROPERTY RECORDED: _____
WATER SUPPLY: ☒ Private ☐ Public ☒ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L ~6%	0-12	gr brn sl/scl fr						
		12-24	sab r cl/c fr	sp sep					
			Holestapb						
			(at 48" lab Wtr)						
2	L ~6%	0-8	gr brn sl/scl fr						PS .3 @ 28"
		8-32	sab brn c	hvy/c/sm fsp sep					
		32-48	wksab brn sl/scl fr	ssp sep					
			common rock fragments						
3	L ~6%	0-8	gr brn sl/scl fr						PS .3 @ 36"
		8-21	sab brn c	hvy/c/sm fsp sep					
		21-36	wksab r cl	fr ssp sep					
		36-48	wksab brn c	fr ssp sep					
			common rock fragments						
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____

EVALUATED BY: _____
OTHER(S) PRESENT: _____