DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: David Martin — APPLICANT: Same
ADDRESS: _____ — APPLICATION DATE: _____ — DATE EVALUATED: 2/7/06
PROPOSED FACILITY: _____ — PROPOSED DESIGN FLOW (.1949): 360 — PROPERTY SIZE: 2.2HA NC
LOCATION OF SITE: Parkertown Rd. — PROPERTY RECORDED: _____
WATER SUPPLY: ☑ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed — Grant Spain

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	CCL 7-8% ROLLING TERRACED	0-17	FF sbk / cl	FR ss - sp	4A				
		18-32	mm sbk / mic cl	FI ss - sp	1/4C 4R				
		33-42	m m sbk / l	FR ss - sp					
		43-48	F VF GR / ls	VFR ss - sp	PS / 4R				.3
2	~CVL	0-15	1 F sbk / l	FR ss - NP					
		16-35	M F sbk mic. cl	FR ss - NP			PS		
		36-48	1 VF GR sl	VFR ss - NP	PS / 4A				
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	P	P
System Type(s)	2570	2570
Site LTAR	.3	.3

OTHER FACTORS (.1946): IRR TOPO
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: Spencer Parker