IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 147321 PIN# 4659152541 DATE 12-28-07

OWNER OR APPLICANT E & J Development Co. PHONE: Business 704-201-6465 Home

ADDRESS PO Box 1065 Huntersville NC 28070

LOCATION Hwy 115 N TL Clear Springs TL Autumn Grove Ln TR Early Frost on left near end

SUBDIVISION Autumn Grove BLOCK / SECTION 2 LOT 32 LOT AREA .51 Ac SITE CLASS. PS DESIGN FLOW 480gpd L.T.A.R. .275 gpd/ft²

Septic Tank: 1000 Gallons: STB 794 Date 12/26/07

Pump Tank: 1000 Gallons: PT 293 Date 1/4/08

Pump Make: Goulds Model WE0-312HN Serial No.

Nitrification Field: No Fields 1 Square Feet 870 Linear Feet 290

No Lines 5 Trench Width 36"* Max Trench Bottom Depth 36" Gravel Depth NA ☐ Gravity ☒ Pressure

☒ New System ☐ Repair ☐ Expansion System Type: I II III (IV) V VI

System Description: LP PPBPS

Repair System Description: LP PPBPS

Maintenance Agreement Required: ☒ Yes ☐ No

☒ House/Mod. Home No. Bedrooms 4

☐ Mobile Home No. Persons 8

☐ Business No. Employees

☐ Other

Water Supply: ☒ Individual ☐ Public ☐ Community

☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments:/Conditions: * per plan specs

Pump tank in-line filter required

Comments:/Conditions: *Plans essentially same as IP with a smaller 42'x40' house foot print *Moved drive-way to Right side of property well in same location. AC 1/8/08

INITIAL SITE SKETCH

See Plan From Rollins Soil & Environmental Services

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: [signature] date 1-4-08 Installed by: A-1 Backhoe OK

Improvement Permit by: Mickey Melville date 12-28-07 Operation Permit by: Wesley Sparks es. date 4/18/08

Authorization to Construct by: Anthony Cobb date 1/8/08 Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK