DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Pruitt Dev
ADDRESS: Lot #52
APPLICANT: _____
APPLICATION DATE: _____
DATE EVALUATED: 5/22/97
PROPOSED FACILITY: _____
PROPOSED DESIGN FLOW (.1949): 360 gpd
PROPERTY SIZE: _____
LOCATION OF SITE: _____
PROPERTY RECORDED: _____
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS 1942 SOIL WETNESS/ COLOR	1943 SOIL DEPTH	1956 SAPRO CLASS	1944 RESTR. HORIZ.	PROFILE CLASS & LTAR
1	LL 4%	0-9"	Brw SCL GR	SS,SP,					.3+
		9"-34"	LtC - Heavy Brw CL mSBK	SS,SP,SE,FI-Fr					
		34"-48"	RdBrw CL mfSBK w/ intrusions of SAp	SS,SP,SE Fr					
2	LL 6%	0-5"	Brw SCL GR	SS,SP					.3
		5"-28"	Heavy CL mSBK	SS,SP,SE,FI-Fr					
		28"-44"	CL mfSBK Some Yellow-Brw Relic mottles	SS,SP,SE,FI-Fr					
		44"	CL mfSBK mixed SAp	SS,SP,SE					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)	Gravity Plastic Chm	Gravity/Pump Plastic Chm
Site LTAR	.3	.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: Monica Dalton
OTHER(S) PRESENT: /