SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Pruitt Development OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED:
PROPOSED FACILITY:
PROPERTY SIZE: pt lot 61
LOCATION OF SITE: Wintwart
WATER SUPPLY: On-Site Well Comm. Well Public Other EVAL. METHOD: Auger Boring Pit Cu

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1937/ 1956 SAPRLT CLASS.	HORIZ LTA
1	Linear 10%	0 to 7	SCL GR		PS	PS	PS	N/A	.3
		7 to 20	Heavy CL SBK	SEAP SS SP					
		30 to 48	CL WSBK	NEAP NS NP					
2	Linear 10%	0 to 6	SCL GR		PS	PS	PS	N/A	.3
		6 to 48	Heavy CL SBK	SEAP SS SP					
3									
4									
5									

SITE LONG-TERM ACCEPTANCE RATE: .3

AVAILABLE SPACE (1955): yes SITE CLASSIFICATION (1968):
EVALUATED BY: E.C. Moore OTHER(S) PRESENT:
COMMENTS: Complex Topography on lower Portion of lot.