4659165066

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 143893 PIN# 465 915 7617.018 Timothy Onyskin DATE 8-28-07

OWNER OR APPLICANT E & J Development Co. / SB Home Builders Business 704-201-6465 Home

ADDRESS P.O. Box 1065 Huntersville NC 28070

LOCATION Hwy 115 N Th Clear Springs on left

SUBDIVISION Autumn Grove BLOCK / SECTION LOT 18 LOT AREA .65 Ac SITE CLASS PS DESIGN FLOW 480gpd L.T.A.R. .275 gpd/ft²

Septic Tank: 1000 Gallons: STB 760 Date 8-10-10
Pump Tank: Gallons: PT (Sheaf) Date
Pump Make: Model Serial No.
Nitrification Field: No Fields 1 Square Feet 1425 Linear Feet 475
No Lines 4 Trench Width 36" Max Trench Bottom Depth 36" Gravel Depth NA ☒ Gravity ☐ Pressure

☒ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI
System Description: 2590 reduction gravity
Repair System Description: LP PPBPS
Maintenance Agreement Required: ☐ Yes ☒ No

☒ House/Mod. Home No. Bedrooms 4
☐ Mobile Home No. Persons 8
☐ Business No. Employees
☐ Other

Water Supply: ☒ Individual ☐ Public ☐ Community

☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments/Conditions:
System 100' from well required

INITIAL SITE SKETCH

See plan from Rollans Soil & Environmental Services

Comments/Conditions: Reviewed floor plans. Essentially in compliance with original permit. Must place house exactly as shown in plan.

AS BUILT SKETCH

1/7/08 OK to move driveway to Right side of Lot. A.G.
1/31/11 Checked SHF lowest line
2/1/11 Checked rest of lines
Used Quick 4 essentially as Drawn

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: date 9-24-07 Installed by: Specialty Septic

Improvement Permit by: Judy Mayfield date 8-28-07 Operation Permit by: Maria H. Dolson date 2/1/11

Authorization to Construct by: Maria H. Dolson RS date 12/6/07 Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK