DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet 12E
PROPERTY ID #:
COUNTY:

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Pruett Dev. G. APPLICANT:
ADDRESS: APPLICATION DATE: DATE EVALUATED: 4/19/97
PROPOSED FACILITY: SFR PROPOSED DESIGN FLOW (.1949): 360gpd PROPERTY SIZE:
LOCATION OF SITE: Lot 6 Windsurf Dr. PROPERTY RECORDED:
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	OTHER PROFILE FACTORS .1943 SOIL DEPTH	OTHER PROFILE FACTORS .1956 SAPRO CLASS	OTHER PROFILE FACTORS .1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L 4%	0-13	sl brn scl	fr					PS .54
		13-37	sabk red cl	fr-fr sp sep					
		37-48	mottled red	fr sp sep sep					
2	L ~5%	0-7	sl brn scl	fr					PS .54
		7-46	sabk red cl	fr sp-ssp sep	sep				
			many brn mottles						
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946):
SITE CLASSIFICATION (.1948):
EVALUATED BY: DCL
OTHER(S) PRESENT:

4/19/97 Const. footprint not staked. Original 50% still in place