DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET____OF_____
PROPERTY I.D.#:_____
PROPERTY RECORDED:_____
COUNTY:_____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Pruett Lot 6 OWNER:__AGENT:__ PHONE:_____
ADDRESS:_____APPLICATION DATE:_____DATE EVALUATED: 11-20-96
PROPOSED FACILITY:_____
PROPERTY SIZE:_____
LOCATION OF SITE: Lot 88 Windward PP
WATER SUPPLY: On-Site Well____Comm. Well___Public___Other_____EVAL. METHOD: Auger Boring___Pit✓___Cut___

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	L 4-6%	0-4	gr-sdy loam cL fr						PS .3
		4-33	ssbk rcl cL	fr ss sp so/p					
		33-55	w mk sbk ye cL	fi ss sp so/p					
2	L 4-6%	0-4	sbk loam cL	fr					PS .3
		4-33	ssbk rcl cL	fr ss sp so/p					
		33-60	w mk sbk ye cL	fi ss sp so/p					
3	L 4-6%	0-32	ss sbk loam ye cl/c	fr ss sp so/p					PS .3
		32-48+	w mk sbk ye, brn cL	fi ss sp so/p					
4									
5									

AVAILABLE SPACE (.1945)_____SITE CLASSIFICATION (.1948):_____SITE LONG-TERM ACCEPTANCE RATE:_____
EVALUATED BY:_____OTHER(S) PRESENT:_____
COMMENTS:_____

pre problems compounded by sign easement