4659240393

11980

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Eugene Houston DATE 9/24/91 PERMIT NO. 4E-2-A-13

PHONE: Business _____ Home 876-0638

LOCATION 115 N, TL ON PARKERTOWN ~ .3 mile on (R)

S. R. No. _____


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (4) Mobile Home ( ) Business ( ) Other Replacing burned M.H with modular

No. Bedrooms _____ No. Bathrooms _____

Garbage Disposal Unit	Yes ( )	No ( )	Character & Porosity of Soil	Existing
Auto. Dishwasher	Yes ( )	No ( )	Percolation Rate	
Auto. Wash. Machine	Yes ( )	No ( )	Topography	
Site Suitable	Yes ( )	No ( )	Depth to Water Table	
			Rock or other impervious formations	

Lot Plan



_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement

Size of Tank 2 Existing Gals.

Nitrification Field:
No. of Lines 2 @ 50'
Sq. Ft. 300 Linear Ft. 100
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by Esther Elder Builders

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: Drop boxes added to eliminate excessive fall on section of trench that runs down the hill

CERTIFICATE OF COMPLETION BY Wesley Sparks RS DATE 9/24/91

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold