IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 072164 PIN# ~~4659 37 9969~~ 4659379823 ✓ DATE 9/14/98

OWNER OR CONTRACTOR Solid Rock Baptist Church PHONE: Business _____ Home _____

ADDRESS 111 Cardinal Lane ~~Troutman, NC. 28166~~ Mrsvl.

LOCATION 115 N - TR Westmoreland Rd. TL Cardinal Lane, 1st building on (L)

SUBDIVISION RV Miller BLOCK / SECTION _____ LOT PT 11 + PT 12 LOT AREA _____ SITE CLASS. PS DESIGN FLOW ~300 L.T.A.R. .25

Septic Tank: EXISTING Gallons: STB _____ Date _____

Pump Tank: _____ Gallons: PT _____ Date _____

Pump Make: _____ Model _____ Serial No. _____

Nitrification Field: No Fields 1 Square Feet 1350 Linear Feet 450

No Lines 3 Trench Width 36" Max Trench Bottom Depth 36" Gravel Depth 12"

☒ New System ☐ Repair System Type: I, (II) III, IV, V, VI

System Description: GRAVITY - CONVENTIONAL

Repair System Description: _____

Maintenance Agreement Required: ☐ Yes ☒ No

☐ House/Mod. Home No. Bedrooms ____

☐ Mobile Home No. Bathrooms ____

☐ Business No. Employees ____

☒ Other CHURCH ~100 MEMBERS


☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Water Supply: ✓ Individual ☐ Public ☐ Community

Comments:/Conditions:

Comments:/Conditions:

INITIAL SITE SKETCH



AS BUILT SKETCH

I understand that this permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months. CARDINAL LANE

Signed: ✱ Diane Petty date 9/17/98

Improvement Permit by: Wesley Sparks RS date 9/15/98

Authorization to Construct by: Wesley Sparks RS date 9/15/98

Installed by: BARRY SIGMON

Operation Permit by: C. [illegible] date 11/5/98

Existing System Inspection by: _____ date _____

HEALTH DEPT. COPY: WHITE INSPECTION COPY (FINAL): GREEN OWNER COPY (FINAL): YELLOW INSPECTION COPY (INITIAL): PINK OWNER COPY (INITIAL): GOLD

BK1093PG0457

FILED
IREDELL COUNTY NC
08/19/98 10:52 AM
BRENDA D. BELL
Register Of Deeds

001339

EASEMENT

Larry Michael Hager and Shirley P. Hager agree to give SOLID ROCK BAPTIST CHURCH a 25 X 35' easement on Lot 11 to install leach lines and repair leach lines in the future.

Signed, Larry Michael Hager 8-18-98
Larry Michael Hager (Date)

Signed, Shirley P. Hager 8-18-98
Shirley P. Hager (Date)

Witnesses:
Signed, Kathy Dempsey
Signed, Cynthia Lee Parris
Signed, Larry Dempsey

Iredell County NC

Larry Michael Hager, Shirley P. Hagen appeared before me this 18th day of August 1998.

Kathy Dempsey
9-17-2001

6/27/98
djp

BK1093PG0456

FILED
IREDELL COUNTY NC
08/19/98 10:51 AM
BRENDA D. BELL
Register Of Deeds

EASEMENT

Sherry Moffitt agrees to give SOLID ROCK BAPTIST CHURCH a 25 X 65' easement on Lot 10 to install leach lines and repair leach lines in the future.

Signed, Sherry Moffitt Plyler 8-6-98
Sherry Moffitt Plyler (Date)

Witnesses:
Signed, Kathy Thompson
Signed, Larry Seifarth
Signed, Carmen LaFerris

Iredell County N.C.
Sherry Moffitt Plyler appeared before me this
6th day of August, 1998
Kathryn Thompson
9-17-2001
Notary

6/27/98
djp

Ronda Hart

From: Doug Sutherland <dougs@lakenormanrealty.com>
Sent: Tuesday, April 25, 2017 12:20 PM
To: Ronda Hart
Subject: septic question - 111 Cardinal Lane, New Cambridge Christian Church/ Solid Rock Baptist Church

Ronda, the minister at New Cambridge answered our question - the church was originally occupied by Solid Rock Baptist Church, so this has to be the right septic record. I hope that helps with your records - I'm going to use it for the New Cambridge property.

thanks,

Doug Sutherland
Lake Norman Realty
(704) 614-2341