15793

IREDELL COUNTY HEALTH DEPARTMENT

4659-44-6832

IMPROVEMENT PERMIT AND CERTIFICATE OF COMPLETION / OPERATIONS PERMIT

OWNER OR CONTRACTOR William T Fann DATE 3/2/93 PERMIT NO. 4E-4-A-6

PHONE: Business _____ Home 528-3233

LOCATION Freeze Crossing Dr. 115-21N TR into Freeze Crossing to 6th lot on (L)

S.R. No. _____

SUBDIVISION NAME Freeze Crossing LOT NO. 6 SECTION OR BLOCK NO. _____

House ☐ Mobile Home ☑ Business ☐ Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ☐ No ☑

Auto. Dishwasher Yes ☑ No ☐

Auto. Wash. Machine Yes ☑ No ☐

Lot Area ~ 20,000 FT²

Soil Characteristics P - c / sa c


Application Rate P - .25 - .3 (wk sp; sF)

Topography P - 20%

Depth to Water Table S - >48"

Rock or other impervious formations S - None observed

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement ✓ Crawl Space



Plot of System (Not to Scale)

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 4 @ 100' x 3'

Sq. Ft. 1200 Linear Ft. 400

Depth of Stone in Lines 12"

Water Supply: Individual ☑ Public ☐

Installed by Dennis Gallihen

I understand and agree to install a septic tank system as specified on this Improvement Permit.

Signed: _____

(IMPROVEMENT PERMIT IS VALID FOR 60 MONTHS FROM DATE OF ISSUE.)

IMPROVEMENT PERMIT BY _____

COMMENTS _____

CERTIFICATE OF COMPLETION BY Wesley Sparks RS. DATE 3/2/93

EXISTING SYSTEM CHECKED BY _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS

Permit is VOID if any unauthorized changes are made in installation of system, and/or if any unapproved changes are made to the site, and/or if any false information is supplied toward securing Improvement Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold