DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET ___ OF ___
PROPERTY I.D.#: ~~EE~~ 4E 447
PROPERTY RECORDED: ___
COUNTY: ___

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: PATRICIA PARRIS OWNER: ~~✓~~ AGENT: ___ PHONE: 663-4235
ADDRESS: FREEZE RD. APPLICATION DATE: 6/14/93 DATE EVALUATED: 6/14/93
MOORESVILLE, NC. PROPOSED FACILITY: 3BD - 2BA HOUSE
PROPERTY SIZE: 150' X 200'
LOCATION OF SITE: FREEZE DR.
WATER SUPPLY: On-Site Well ✓ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	P	0-10	w sbk-F c	1:1	S	P	P	S	
	P	11-20	w sbk F c	1:1	S	P	P	S	
	P	21-40	VF SSBK c	1:1	S	P	P	S	
	P	41-46	VFR SBK c	1:1	S	P	P	P	.25-.3
2									
3									
4									
5									

AVAILABLE SPACE (.1945) P SITE CLASSIFICATION (.1948): P SITE LONG-TERM ACCEPTANCE RATE: .25-.3
EVALUATED BY: Sparks OTHER(S) PRESENT: John Craver
COMMENTS: FIRM TO 36-37", LOOSE TRANSITION AREA.