4659 456900

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR RANDY WOODWARD DATE 1/6/88 PERMIT NO. _____

PHONE: Business _____ Home 664-6864

LOCATION 21 N TR (ACROSS FROM PARKERTOWN RD.) BY CHURCH PASS ELECTRIC SUBSTATION and Curve L. ON RIGHT S. R. No. _____

SUBDIVISION NAME FOX RUN LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Clayey
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	~ .4gpd/ft²
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	6-8%
Site Suitable	Yes ( )	No ( )	Depth to Water Table	4'+
			Rock or other impervious formations	none obs.

Lot Area ~ 7 ACRES

_____ Basement with Plumbing ✓ Basement without Plumbing _____ No Basement



Plot of System NTS

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 900 Linear Ft. 300

Depth of Stone in Lines 12"

Water Supply: Individual (✓)

Public ( )

Installed by Wes Lytton

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY ACP

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Andrew C. Price DATE 1/6/88

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold