16328

IREDELL COUNTY HEALTH DEPARTMENT

PIN# 4659-48-0930

IMPROVEMENT PERMIT AND CERTIFICATE OF COMPLETION / OPERATIONS PERMIT

OWNER OR CONTRACTOR Larry W. Houston DATE 5/13/93 PERMIT NO. 4F-1-A-34,35,36

PHONE: Business _____ Home 508-3058

LOCATION CARDINAL LN; I15N, TR WESTMORLAND, TL CARDINAL TO LAST HOUSE ON (R)

SUBDIVISION NAME CARDINAL ACRES LOT NO. 34,35,36 S.R. No. _____ SECTION OR BLOCK NO. _____

House ☑ Mobile Home ☐ Business ☐ Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ☐ No ☑

Auto. Dishwasher Yes ☑ No ☐

Auto. Wash. Machine Yes ☑ No ☐

Lot Area Existing

Soil Characteristics Existing System


Application Rate _____

Topography _____

Depth to Water Table _____

Rock or other impervious formations _____

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement ✓ Crawl Space



Plot of System (Not to Scale)

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 900 Linear Ft. 300

Depth of Stone in Lines 12"

Water Supply: Individual ☐ Public ☑ COMM WATER

Installed by Richard Abernathy

I understand and agree to install a septic tank system as specified on this Improvement Permit.

Signed: _____

(IMPROVEMENT PERMIT IS VALID FOR 60 MONTHS FROM DATE OF ISSUE.)

IMPROVEMENT PERMIT BY _____

COMMENTS _____

CERTIFICATE OF COMPLETION BY _____

EXISTING SYSTEM CHECKED BY Wesley Sparks RS, DATE 5/13/93

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS

Permit is VOID if any unauthorized changes are made in installation of system, and/or if any unapproved changes are made to the site, and/or if any false information is supplied toward securing Improvement Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold