DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet 1 of 1
PROPERTY ID #:
COUNTY:

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Jennifer Dixon APPLICANT: Same
ADDRESS: Milo Ln. APPLICATION DATE: DATE EVALUATED: 12/19/95
PROPOSED FACILITY: PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE:
LOCATION OF SITE: 115N-2W TL Milo Ln. lot on R before curve in drive PROPERTY RECORDED:
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LAND-SCAPE POSITION/ SLOPE %	HORI-ZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	NCC TERRACE	0-10	CL SBK	fri SS,SP	PS	PS	PS	PS	.25
		11-32	SCL WSBK	fri SS,P					
		33-46	msCL WSBK	firm SS,SP					
2									
3									
4			1440 FT²						
			480 FT						
			4@120x3'						
			360 FT INFILTRATOR						

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	S	S
System Type(s)	CONV	
Site LTAR	.25	

OTHER FACTORS (.1946):
SITE CLASSIFICATION (.1948):
EVALUATED BY: Freeman - Sparks
OTHER(S) PRESENT: