SOIL/SITE EVALUATION

(Continuation Sheet)

DEPARTMENT OF ENVIRONMENT
AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

Sheet ____ of ____

Sheperds Bluff Lot 29

C B A D

PROPERTY ID #: _____
DATE OF EVALUATION: _____
COUNTY: _____

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
P 29 A	L/6-10	0-10	Bsl sr	Fr SS SP SEXP		60	—	—	PS 0.3
		10-40	RC wf Abk	Fr SSSP SEXP	f. Sap				
		40-60	Rcl wsbk	Fr SS SP SEXP	C Sap				
P 29 B	L/6-10	0-24	RB c wmsbk	FrSSSP SEXP	-				PS 0.3 - 0.35
		24-40	Rcl wfsbk	Fr SSSP SEXP	C Sap				
		40-60	verys. sl mass	Fr SS SP SEXP	f, cl incl,				
P 29 C	L/6-10	0-30	RC mf Abk/sbk	FrSSSP SEXP		60	—	—	PS 0,3
		30-60	Rcl wsbk	Fr SSSP SEXP	C Sap				
P 29 D	L/6-10	0-46	BR C mf Abk/sbk	Fr SS SP SEXP		64	—	—	PS 0,3
		46-64	R cl wmsbk	Fr SS SP SEXP	C Sap				

COMMENTS: _____

DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Shepherd's Bluff LLC
ADDRESS: _____
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____
LOCATION OF SITE: Shep Bluff # 29

APPLICATION DATE 6/4/07
DATE EVALUATED: _____
PROPERTY SIZE: _____
PROPERTY RECORDED: _____

WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	A Front Rt	0-10	Brw SCL						PS .3
		10-26	R C	SBK/ABK					
		26-40	R C/C	SBK SS, SP, SE					
		40-50	R C/L	FR SS SP, SE					
2	B Back Rt	0-10	Brw SCL	w/SBK SS, SP, SE					PS .3 to .35
		10-40	R m	SBK/ABK C FR, SS, SP, SE					
		40-60	SL	SAP/ Mass FR, SS SP, SE					
3	C Back Left	0-36	RC m-w	ABK/SBK FR, SS, SP, SE					PS .3
		36-60	R CL	w/SBK FR, SS SP, SE					
4		0-10	Brw SCL						PS .3
		10-36	R C	SBK/ABK					
		36-60	R CL	w/ many SAP Inclus.					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____

COMMENTS: _____