EPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
IVISION OF ENVIRONMENTAL HEALTH
N-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

WNER: BILLY ALLEN — APPLICATION DATE 2/07
DDRESS: _____ — DATE EVALUATED: 1/07
ROPOSED FACILITY: RES — PROPOSED DESIGN FLOW (.1949): 480 GPD — PROPERTY SIZE: _____
OCATION OF SITE: LOT 60 SHEPHERDS BLUFF — PROPERTY RECORDED: _____
WATER SUPPLY: ☑ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☑ Pit ☐ Cut — TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
P 1	LSS 10-15%	0-18	RC MASSY	ABK fri SSSPSoaP	—	48"	—	—	PS .3 gpd/ft²
		18-48	RCL WFSBK	fri SSSPSoaP					
P 2	LSS 10-15%	0-8	BSCL GR	fri SSSPSoaP	—	48"	—	—	PS .3 gpd/ft²
		8-24	RC MA/SBK	fri SSSPSoaP					
		24-48	RCL WFSBK	fri SSSPSoaP					
P 3	LSS 10-15%	0-10	FILL		—	48"	—	—	PS .3 gpd/ft²
		10-24	RC MFSBK	fri SSSPSoaP					
		24-48	RCL WFSBK	fri SSSPSoaP					
P 4	LSS 10-15%	0-20	RC MFSBK	fri SSSPSoaP	—	52"	—	—	PS .3 gpd/ft²
		20-52	RCL WSBK	fri SSSPSoaP					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	840 ft²	840 ft²
System Type(s)	PPBPS	PPBPS
Site LTAR	.3	.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: Rollan Soil & Env. Services
OTHER(S) PRESENT: _____

COMMENTS: _____

DEPARTMENT OF ENVIRONMENT
AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SOIL/SITE EVALUATION

(Continuation Sheet)

Lot 60
Shepherds Bluff

Sheet ____ *of* ____

PROPERTY ID #: ____________
DATE OF EVALUATION: ____________
COUNTY: ____________

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
P 5	LSS 10-15%	0-7	BSCL GR	fr SSSP Sexp	—	54"	—	—	.3 Suit/Prov
		7-28	RC MSBK	fr SSSP Sexp					
		28-54	RCL MWSBK	fr SSSP Sexp					

COMMENTS: ____________