Looks like on Pin 4659606061 158 Belk Rd.

IREDELL COUNTY HEALTH DEPARTMENT

11928

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Bradley Belk DATE April 4 '91 PERMIT NO. 14-B-16B portion

PHONE: Business _____ Home _____

LOCATION 115-21 N. Tr just before Vanderburg Methodist Church ~1000' off road on right

S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2½

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site ~~Suitable~~ PS Yes (✓) No ( )
Lot Area 3.772 Ac

Character & Porosity of Soil PS sandy clay
Percolation Rate 4
Topography 10-15%
Depth to Water Table 34
Rock or other impervious formations none obs.

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals. 1000 p.T.

Nitrification Field:
No. of Lines 2
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by Jimmy Beam

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

Access Road

IMPROVEMENTS PERMIT BY _____

COMMENTS: Alarm not permanently mounted when tested.

Operation permit

CERTIFICATE OF COMPLETION BY D. H. Lyon, REHS DATE 4-4-91

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold