IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Kingdom Hall of Jehovah's Witness DATE 11-17-86 PERMIT NO. 602

PHONE: Business _____ Home _____

LOCATION 115-21N on Rt across from Shepherds School

_____ S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home ( ) Business ( ) Other Church - ~ 100 members


No. Bedrooms _____ No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes ( )	No (✓)	
Site Suitable	Yes (✓)	No ( )	

Lot Area ~2Ac

Character & Porosity of Soil Clay
Percolation Rate 40
Topography 2-4%
Depth to Water Table 40+
Rock or other impervious formations none obs.

_____ Basement with Plumbing _____ Basement without Plumbing ___✓___ No Basement



Plot of System

Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 1500 Linear Ft. 500
Depth of Stone in Lines 6"
Water Supply: Individual (✓)
Public ( )

Installed by Clifford Baker Conover

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY DRH

COMMENTS: _____

CERTIFICATE OF COMPLETION BY David R. Hinson, RS DATE 11-17-86

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold