4659655162

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Randy Fesperman DATE 11/23/87 PERMIT NO.

PHONE: Business Home 664-4337

LOCATION 21 N - 115 N TR Shepherd Rd. TL. Shepherd Field

S. R. No.

SUBDIVISION NAME Sheppard Field LOT NO. 12 SECTION OR BLOCK NO.

House ( ) Mobile Home (✓) Business ( ) Other


No. Bedrooms 2 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Character & Porosity of Soil Clay
Percolation Rate ~.35 gpd/ft²
Topography 8% - 12%
Depth to Water Table 4'+
Rock or other impervious formations none observed

Lot Area .993 ACRE

____ Basement with Plumbing ____ Basement without Plumbing ✓ No Basement



Plot of System NOT TO SCALE

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 680 Linear Ft. 240
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by SELF Randy Fesperman

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed:

IMPROVEMENTS PERMIT BY ACG

COMMENTS: SET MOBILE HOME AT LEAST 5' off of TANK / DRAINLINES.

CERTIFICATE OF COMPLETION BY Andrew C. Price DATE 11/23/87

EXISTING SYSTEM CHECKED BY: DATE

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold