13049

4659659459

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Ronald Charles Tucker DATE 7/3/91 PERMIT NO. 40-1-A-6

PHONE: Business _____ Home 663-0121

LOCATION Shepard Rd. 3/4 mile on (L) on to gravel to Lot no 6 on L in curve

SUBDIVISION NAME _____ S. R. No. _____

LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 20,000 Ft 2

Character & Porosity of Soil clay - sft, sbk


Percolation Rate .3

Topography 2-6%

Depth to Water Table >48"

Rock or other impervious formations None observed

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 2 @ 130' x 3'

Sq. Ft. 780 Linear Ft. 260

Depth of Stone in Lines 12"

Water Supply: Individual (✓)

Public ( )

Installed by Larry Beam

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Wesley Sparks R.S. DATE 7/3/91

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold