IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 140412 PIN# 4659 66 0482 DATE 2/6/07

OWNER OR APPLICANT Shepherds Bluff LLC / Ogden Construction PHONE: Business Home

ADDRESS 111 B Rawhide Dr. Mooresville, NC. 28117

LOCATION 115 N TR Shepherds Rd TL Shepherds Bluff Dr. TL Bluff Meadow TL Sheep Path Ln., house on (R)

SUBDIVISION Shepherds Bluff BLOCK / SECTION 5 LOT 37-37A LOT AREA .97 SITE CLASS PS DESIGN FLOW 480 L.T.A.R. .25

Septic Tank: 1000 Gallons; STB 794 Date 10-20-01
Pump Tank: 1000 Gallons; PT 27 Date 1-24-08
Pump Make: _____ Model _____ Serial No. _____
Nitrification Field: No Fields 1 Square Feet 960 Linear Feet 320
No Lines 4 Trench Width 3' Max Trench Bottom Depth 3'

☒ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI
System Description: Trans Bond - 16" PBBPS
Repair System Description: 5 conn
Maintenance Agreement Required: ☒ Yes ☐ No

☒ House/Mod. Home No. Bedrooms 4
☐ Mobile Home No. Persons ____
☐ Business No. Employees ____
☐ Other

Water Supply: ☒ Individual ☐ Public ☐ Community

Gravel Depth No ☐ Gravity ☒ Pressure ☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments:/Conditions: System design prepared by Rollins Soil & Environmental Services.

Comments:/Conditions: 11/2/07 Reviewed Floor plans, essentially in Compliance with orginal permit. 4/2/08 Checked panel lines, installed a SD Drawn 4/3/08 Checked

INITIAL SITE SKETCH

(1) Must have Rollins Specifications and Site Plan before attempting installation of this system.

(2) House Plans must be approved by ICHD before Auth. to Construct will be issued

(3) Plat for Easement Area on Lot 37A must be properly recorded and presented to ICHD. before Auth. to Construct will be issued.

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☐ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: _____ date 2/9/07 Installed by: Richard Abernathy

Improvement Permit by: Wesley Sparks R.S. date 2/6/07 Operation Permit by: Wesley Sparks R.S. date 6/27/08

Authorization to Construct by: Marcia H. Johnson R.S. date 11/2/07 Existing System Inspection by: _____ date _____

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK