IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 144350 PIN# 4659662891.000 DATE 8/10/07

OWNER OR APPLICANT Shepherd's Bluff, LLC (Billy Allen) PHONE: Business _____ Home _____

ADDRESS 111-B Raceway Dr. Mooresville, NC 28115

LOCATION Shepherds Rd. TR on Shepherd's Bluff Dr. on Left

SUBDIVISION Shepherds Bluff BLOCK / SECTION _____ LOT 55 LOT AREA 0.46 SITE CLASS. PS DESIGN FLOW 360 L.T.A.R. 0.275

Septic Tank: 1000 Gallons; STB 312 Date 4-15-07

Pump Tank: _____ Gallons; PT _____ Date _____

Pump Make: _____ Model _____ Serial No. _____

Nitrification Field: No Fields 1 Square Feet 990' Linear Feet 330

No Lines 4 Trench Width 36" Max Trench Bottom Depth 36"

☑ New System ☐ Repair ☐ Expansion System Type: I (II) III IV V VI

System Description: Gravity 25% Reduction

Repair System Description: Pump 50% Reduction

Maintenance Agreement Required: ☐ Yes ☑ No Initial

Gravel Depth N/A ☑ Gravity ☐ Pressure ☐ Slab ☑ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

☑ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 3 No. Persons _____ No. Employees _____

Water Supply: ☑ Individual ☐ Public ☐ Community

Comments:/Conditions: * Per Plan specs

Comments:/Conditions:

INITIAL SITE SKETCH

*See plans from Rollans Soil + Env. Services

AS BUILT SKETCH

11/2/07 Installed Quick 41, essentially as Drawn

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☑

Signed: _____ date 8/13/07

Improvement Permit by: Anthony Coker Jr. date 8/10/07

Authorization to Construct by: Anthony Coker Jr. date 8/14/07

Installed by: Larry Beam Grading

Operation Permit by: Mark Dotson date 11/2/07

Existing System Inspection by: _____ date _____

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK