IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Vanderburg methodist DATE 1-11-74 PERMIT NO. 1

PHONE: Business _____ Home _____

LOCATION US 21 N & 115 N on right

S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House ( ) Mobile Home ( ) Business ( ) Other Church

No. Bedrooms _____ No. Bathrooms 4
Garbage Disposal Unit Yes (-) No ( )
Auto. Dishwasher Yes (-) No ( )
Auto. Wash. Machine Yes ( ) No ( )
Site Suitable Yes (✓) No ( )

Character & Porosity of Soil cecil sandy loam
Percolation Rate not taken
Topography 2 to 10 slope
Depth to Water Table lot+
Rock or other impervious formations 5 to 15' to bet rock

Lot Area [redacted] over 2 acres

Ex well



Plot of System

Size of Tank Existing Tank Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 800 Linear Ft. 300
Depth of Stone in Lines 12" to 15"
Water Supply: Individual (✓)
Public ( )

Installed by Eddie Yountz

IMPROVEMENTS PERMIT BY _____

COMMENTS: Solid line ~~from~~ From Tank to Distribution Box is 6" in diameter has Two Clean outs.

CERTIFICATE OF COMPLETION BY J. C. Wood DATE 1-11-74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold