DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: ___

# SOIL/SITE EVALUATION
## *for* ON-SITE WASTEWATER SYSTEM

OWNER: Harold Livengood — APPLICANT: ___
ADDRESS: 290 Shepherd Rd. — APPLICATION DATE: ___ — DATE EVALUATED: ___
PROPOSED FACILITY: 3BD - 1BA — PROPOSED DESIGN FLOW (.1949): 360 — PROPERTY SIZE: 1.0
LOCATION OF SITE: On L of driveway at 290 — PROPERTY RECORDED: ___
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

| PROFILE # | 1940 LANDSCAPE POSITION/ SLOPE % | HORIZON DEPTH (IN.) | SOIL MORPHOLOGY (.1941) 1941 STRUCTURE/ TEXTURE | 1941 CONSISTENCE/ MINERALOGY | OTHER PROFILE FACTORS 1942 SOIL WETNESS/ COLOR | 1943 SOIL DEPTH | 1956 SAPRO CLASS | 1944 RESTR. HORIZ. | PROFILE CLASS & LTAR |
|---|---|---|---|---|---|---|---|---|---|
| 1 | CC/T | 0-7 | SBK cl | FR SS SP | S | S | PS | S | PS .3 |
| | | 8-29 | wk Hcl | FI S P | | | | | |
| | | 30-49 | wk GR c/SAP | FR S NP | | | | | |
| 2 | | | | | | | | | |
| 3 | | | | | | | | | |
| 4 | | | | | | | | | |

| DESCRIPTION | INITIAL SYSTEM | REPAIR SYSTEM |
|---|---|---|
| Available Space (.1945) | PS | PS |
| System Type(s) | Conv | Ch Plas |
| Site LTAR | .3 | .25 |

OTHER FACTORS (.1946): ~ CC
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: [signature]
OTHER(S) PRESENT: Harold Livengood