4659-82-0598

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Thomas Donaldson DATE April 11, '88 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 115-21N TR 2389 (Shepherd Rd.) TR Roseland Court at end on Rt. S. R. No. _____

SUBDIVISION NAME Roseland Heights LOT NO. 12, 13 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other Repair


No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site ~~Suitable~~ PS	Yes (✓)	No ( )	

Lot Area ½ Acre

Character & Porosity of Soil clay
Percolation Rate 3, 4
Topography 4-6%
Depth to Water Table 4ft
Rock or other impervious formations none obs.

_____ Basement with Plumbing _____ Basement without Plumbing ___✓___ No Basement



Plot of System Street

Size of Tank Existing Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"
Water Supply: Individual ( )
Public (✓)
Community Well
Installed by Wayne Potts

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed _____

IMPROVEMENTS PERMIT BY DRH

COMMENTS: _____

CERTIFICATE OF COMPLETION BY [signature], RS. DATE 4-11-88

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold