4659820598

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Dogwood Const. DATE 10-10-24 PERMIT NO. 299

PHONE: Business Cell Phone Home

LOCATION US 21 & US 21 N TR on 2329 Chandler Rd TR next Rural Rd last house on right 1st lot S. R. No. 2329

SUBDIVISION NAME Roseland Heights LOT NO. 15 SECTION OR BLOCK NO.

House (✓) Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit Yes ( ) No (✓)


Auto. Dishwasher Yes ( ) No (✓)

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area Open Sq. Ft.

Character & Porosity of Soil Sandy clay loam Percolation Rate 30 min/inch Topography Rolling Depth to Water Table 18+ in Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 450 Linear Ft. 210
Depth of Stone in Lines 12"

Water Supply: Individual ( )
Public (✓)

Installed by Eddie Yountz

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: Remove Maple Trees that are near septic Tank and with Eicatum lines.

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 10-30-24

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold