DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ____
PROPERTY ID #: ____
COUNTY: ____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Max Spear / Roseland Lot 12
ADDRESS: ____ APPLICATION DATE ____
PROPOSED FACILITY: 3BR PROPOSED DESIGN FLOW (.1949): 360 gpd DATE EVALUATED: ____
LOCATION OF SITE: Roseland Rd. PROPERTY SIZE: ____
WATER SUPPLY: ☐ Private ☒ Public ☒ Well ☐ Spring ☐ Other ____ PROPERTY RECORDED: ____
EVALUATION METHOD: ☒ Auger Boring ☒ Pit ☐ Cut TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ M

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
P 1	Lot 12 4/6-10%	0-13	BSCL WSBK	FrSSSPSEXP		47	-	-	PS 0.275
		13-54	RY SC WSBK	" " " "	-f YBs				
		34-47	RB VWSBK	" " " "	-fsap				
P 2	Lot 12 4/6-10%	0-12	BSCL WSBK	FrSSSPSEXP		47	-	-	PS 0.25-38"
		12-35	RBSCWSBK	" " " "	-f YBs				
		35-47	RCWSBK	" " " "	-c YBs -chr. 2's @38"				
B 3	Lot 12 4/6-10%	0-5	BSLSR	FrSSSPSEXP		50	-	-	PS 0.3
		5-40	RY SCL WSBK	" " " "	-fsap				
		40-50	R SC WSBK/MK	" " " "	-fsap				
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)	25%	
Site LTAR	0.25	

OTHER FACTORS (.1946): ____
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: SAR
OTHER(S) PRESENT: ____

COMMENTS: ____