4659-82-0728

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Dogwood Court DATE 4-2-04 PERMIT NO. 70

PHONE: Business _____ Home _____

LOCATION US 21 HWY 15 North TR on 2389 on Front of Shiloh School next Road to right S. R. No. 2389

SUBDIVISION NAME Roseland Heights LOT NO. 4 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes	( )	No	(✓)	
Auto. Dishwasher	Yes	(✓)	No	( )	
Auto. Wash. Machine	Yes	(✓)	No	( )	
Site Suitable	Yes	(✓)	No	( )	

Character & Porosity of Soil red clay gravel clay (Rocky Soil)
Percolation Rate 45 min/inch
Topography Slope to lot
Depth to Water Table _____
Rock or other impervious formations None

Lot Area 14,000 Square feet



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 300 Linear Ft. 300
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)

Installed by Eddie Younts

IMPROVEMENTS PERMIT BY _____

COMMENTS: Approx 6" of Top Soil is Fair however Porosity at bottom of Trench Hitch is Good

CERTIFICATE OF COMPLETION BY J. E. Moore DATE 4-7-04

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold