IREDELL COUNTY HEALTH DEPARTMENT 4059-82-1845

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR J. Banks Brown DATE 4-29-82 PERMIT NO. 120

PHONE: Business _____ Home _____

LOCATION 115 North TR 2389 TR 2483 At end of pavement on left

S. R. No. _____


SUBDIVISION NAME Roseland Heights Sec II LOT NO. 23 SECTION OR BLOCK NO. _____

House (X) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (X)	Character & Porosity of Soil	Clay loam
Auto. Dishwasher	Yes ( )	No (X)	Percolation Rate	45
Auto. Wash. Machine	Yes (X)	No ( )	Topography	Rolling
Site Suitable	Yes (X)	No ( )	Depth to Water Table	Unknown
Lot Area 19600 ft²			Rock or other impervious formations	None observed

_____ Basement with Plumbing _____ Basement without Plumbing X No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 750 Linear Ft. 250
Depth of Stone in Lines 16"

Water Supply: Individual ( )
Public (X) Community

Installed by Eddie Yountz

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Fred Clemmer

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Fred Clemmer DATE 4-29-82

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold