4659831097

# IREDELL COUNTY HEALTH DEPARTMENT

## (SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR (Marlo Corp.) Floyd Greene DATE 6-17-84 PERMIT NO. 270

PHONE: Business _____ Home _____

LOCATION 115 N TR 2389 about ½ mile TR Shepard valley 1 mile on R (below gas line)

SUBDIVISION NAME Shepard Valley LOT NO. 7 S. R. No. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (X) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

| | | |
|---|---|---|
| Garbage Disposal Unit | Yes ( ) | No (X) |
| Auto. Dishwasher | Yes (X) | No ( ) |
| Auto. Wash. Machine | Yes (X) | No ( ) |
| Site Suitable | Yes (X) | No ( ) |

Lot Area 20,000+ sq ft

Character & Porosity of Soil Clay loam


Percolation Rate 120 min/in - 1 day

Topography R 3-8%

Depth to Water Table 4'

Rock or other impervious formations None obs.

_____ Basement with Plumbing _____ Basement without Plumbing X No Basement




Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 4

Sq. Ft. 120 Linear Ft. 240

Depth of Stone in Lines 12"

Water Supply: Individual (X)

Public ( )

Installed by Bowles

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Fred Memory

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Charles L. Dowell

EXISTING SYSTEM CHECKED BY: _____ DATE 5-17-84

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS. DATE _____

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR John Gillespie DATE 6-2-86 PERMIT NO. 311

PHONE: Business _____ Home _____

LOCATION 21 W TR on Shepherd Rd 2nd Rt TR 1st MH on Rt. S. R. No. _____

SUBDIVISION NAME Shepherd Valley LOT NO. 7 SECTION OR BLOCK NO. II


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area 1/2 acre+

Character & Porosity of Soil _____
Percolation Rate _____
Topography _____
Depth to Water Table Existing System
Rock or other impervious formations _____

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System

Size of Tank _____ Gals.
Nitrification Field:
No. of Lines _____
Sq. Ft. _____ Linear Ft. _____
Depth of Stone in Lines _____
Water Supply: Individual ( )
Public ( )

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

The proposed / existing OUT BUILDING addition does not appear to impact the existing septic system.
**NOTE: BLDG IN REAR OF M H.
Wesley Parks R.S.
Date: 9/10/09
ICHD-Environmental Health Division

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: L. C. Moore DATE 6-2-86

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold