4659834408

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR (Mardo Corp) Floyd Green DATE 11-8-84 PERMIT NO. 400

PHONE: Business _____ Home _____

LOCATION Sheperd Road TR just past the subdivison on dirt road go to the end S. R. No. _____

SUBDIVISION NAME Sheperd Valley LOT NO. 89 SECTION OR BLOCK NO. _____

House ( ) Mobile Home (X) Business ( ) Other _____


No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit Yes ( ) No (X)
Auto. Dishwasher Yes (X) No ( )
Auto. Wash. Machine Yes (X) No ( )
Site Suitable Yes (X) No ( )

Character & Porosity of Soil clay loam
Percolation Rate 0.5 gall/ft²/day
Topography 6-10%
Depth to Water Table 4+
Rock or other impervious formations None observed

Lot Area 20,000 ft²

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 12"
Water Supply: Individual (X)
Public ( )

Installed by Bowles

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: X _____

IMPROVEMENTS PERMIT BY Charles K. Barnett & Fred Clemmer

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Charles K. Barnett DATE 11-8-84

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold