4659836394

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Marla Corporation (Floyd Greene) DATE 12-21-84 PERMIT NO. 433

PHONE: Business _____ Home _____

LOCATION 115 N TR 2389 ½ mile 12th lot on R

S. R. No. _____

SUBDIVISION NAME Sheperd Valley LOT NO. 12 SECTION OR BLOCK NO. _____


House ( ) Mobile Home (X) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (X)	Character & Porosity of Soil	clay	
Auto. Dishwasher	Yes (X)	No ( )	Percolation Rate	0.3 gal/ft²/day	
Auto. Wash. Machine	Yes (X)	No ( )	Topography	2-8% slope	
Site Suitable	Yes (X)	No ( )	Depth to Water Table	4'	
			Rock or other impervious formations	none observed	

Lot Area _____

_____ Basement with Plumbing _____ Basement without Plumbing X No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 2

Sq. Ft. 120 Linear Ft. 120

Depth of Stone in Lines 12"

Water Supply: Individual (X)
Public ( )

Installed by J. R. Bowles

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Fred Clemmer

COMMENTS: seal d-box

CERTIFICATE OF COMPLETION BY Charles K. Bennett DATE 12-21-84

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold