4659850248

14963

IREDELL COUNTY HEALTH DEPARTMENT

IMPROVEMENT PERMIT AND CERTIFICATE OF COMPLETION / OPERATIONS PERMIT

OWNER OR CONTRACTOR Barbara J Johnson DATE 7/24/92 PERMIT NO. 40-A-35

PHONE: Business _____ Home 664-2456

LOCATION 21N, TR on SHEPARD RD, ~ 1 mile on (R) in field

S.R. No. _____

SUBDIVISION NAME N/A LOT NO. _____ SECTION OR BLOCK NO. _____

House ☐ Mobile Home ☑ Business ☐ Other _____

No. Bedrooms 2 No. Bathrooms 2 Soil Characteristics Existing System


Garbage Disposal Unit Yes ☐ No ☑ Application Rate _____

Auto. Dishwasher Yes ☑ No ☐ Topography _____

Auto. Wash. Machine Yes ☑ No ☐ Depth to Water Table _____

Lot Area ~ 2 AC Rock or other impervious formations _____

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement ✓ Crawl Space



Plot of System (Not to Scale)

Size of Tank Existing 1000 Gals.

Nitrification Field:

No. of Lines 3 / 70' 60' 70' x 3'

Sq. Ft. 600 Linear Ft. 200

Depth of Stone in Lines 12"

Water Supply: Individual ☑ Public ☐

Installed by _____

I understand and agree to install a septic tank system as specified on this Improvement Permit.

Signed: _____

(IMPROVEMENT PERMIT IS VALID FOR 60 MONTHS FROM DATE OF ISSUE.)

IMPROVEMENT PERMIT BY Shepard Rd.

COMMENTS _____

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY Wesley Sparks RS. DATE 7/24/92

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS

Permit is VOID if any unauthorized changes are made in installation of system, and/or if any unapproved changes are made to the site, and/or if any false information is supplied toward securing Improvement Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

9:30

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR James Berry DATE 6-24-86 PERMIT NO. 287

PHONE: Business _____ Home _____

LOCATION 21 & 115N TR on Sheperd Rd go ~.7mile lot on R just past enterance into Sheperd field Subdivision S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____


No. Bedrooms 2 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Character & Porosity of Soil Clay
Percolation Rate .4 gal/ft2/day
Topography 2-8%
Depth to Water Table 41"
Rock or other impervious formations none obs

Lot Area 2 acres

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 600 Linear Ft. 3200
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: James L Berry

IMPROVEMENTS PERMIT BY Charles K. Bennett

COMMENTS: keep system shallow (no more than 3.5' deep) and follow contour

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold