# IREDELL COUNTY HEALTH DEPARTMENT

S TESVILLE 704-878-5305 MOORESVILLE 704-664-5281

## IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTR CT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 129752 PIN# 4659874296.002 4659872105 DATE 10-3-05

OWNER OR CONTRACTOR Shepherds Bluff LLC PHONE: Business (704)664-7029 Home

ADDRESS 111-B Raceway Dr. Mooresville, NC 28117

LOCATION Hwy 115 North TR Shepherd's Road TL Shepherd's Bluff 2nd lot on right

SUBDIVISION Shepherd's Bluff BLOCK / SECTION LOT 2 LOT AREA .46 Acre SITE CLASS PS DESIGN FLOW 360 gpd L.T.A.R. .4 (SAP)

Septic Tank: 1000 Gallons; STB 794 Date 1/17/06

Pump Tank: Gallons; PT Date

Pump Make: Model Reg./Des Serial No. Reg./Design

Nitrification Field: No Fields 1 Square Feet 607.5/735 Linear Feet 225'/245'

No Lines 3 Trench Width 36" Max Trench Bottom Depth 36"

☒ New System ☐ Repair System Type: I, II, III, IV, V, VI

System Description: Gravity-25% Reduction

Repair System Description: Pump-25% Reduct. "Accepted"

Maintenance Agreement Required: ☐ Yes ☐ No

☒ House/Mod. Home No. Bedrooms 3

☐ Mobile Home No. Bathrooms

☐ Business No. Employees

☐ Other

Gravel Depth N/A ☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Water Supply: ☒ Individual ☐ Public ☐ Community

Comments:/Conditions:

Septic permit approved for attached plan, designed by Rolins Soil & Environmental Services

Comments:/Conditions: IQ4W installed as per Site Plan

INITIAL SITE SKETCH

See attached plan & drawing for Septic System Layout.

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: date 10/6/05 Installed by: Penn Warden

Improvement Permit by: Maria H. Dotson RS date 10/3/05 Operation Permit by: Wesley Sparks RS. date 3/27/06

Authorization to Construct by: Maria H. Dotson RS date 10/3/05 Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK