DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: ___

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: ___ APPLICATION DATE ___
ADDRESS: ___
PROPOSED FACILITY: ___ PROPOSED DESIGN FLOW (.1949): ___ DATE EVALUATED: 7-18-02
LOCATION OF SITE: Lot 69 phs 2 Brook blvd PROPERTY SIZE: ___
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other ___ PROPERTY RECORDED: ___
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LAND-SCAPE POSITION/ SLOPE %	HORI-ZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1		0-6	gr brwsl ls	frssp					.35.4
		6-25	mksab sdl	frssp common mi sap					
		25-60	mksab msl	frssp					
						gets better with depth			
2		0-6	gr-mksab brwsl	frssp					.3+
		6-25	sab ac	frss sl pl common mi sap					
		25-45	mksab yel sap	frssp					
		45-60	mksab sl sap	frss mpb				gets better with depth	
3	Pocosin Area	0-28	mksab brn-brwsl	frssp					.3
		28-57	mksab RCL	fr sssp common mi sap					
			Reduced @ 45"						
					Needs Friend Drain				
4	MK 69A 4-2-02	0-5	mksab brwsl	frssp					.3+
		5-20	mksab rc	fi sp few mi sap					
		20-32	mksab yesl	frssp common-many mi sap					
		32-60	LS sap	frssp					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): ___
EVALUATED BY: ___
OTHER(S) PRESENT: ___

COMMENTS: ___