DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: _____ APPLICATION DATE _____
ADDRESS: _____
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ DATE EVALUATED: 2-19-02
LOCATION OF SITE: Lot 77 continued from 2 backhoe PROPERTY SIZE: _____
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☑ Spring ☐ Other _____ PROPERTY RECORDED: _____
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LAND-SCAPE POSITION/ SLOPE %	HORI-ZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
5		0-17	gr brn sl/scl fri ss sp						
		17-56	wk AB-massive few R mottles	ybrn sc fi-vfi sp-vss vp exp	17"+				4
6		0-7	gr brn sl/scl fri ss sp						
		7-15	wk SAB pbrn c/scl common gbrn mottles fri ss sp						
		15-61	wk AB-massive sc fi-fm common mixed sap	gleyed @ 31"+ exp	31"+				4
			Rock inclusions						
7		0-7	gr-wk sab brn sl/scl fri ss sp						App. = 1 mg/day
		7-17	wk SAB RC/cl fri ss sp-ss vp	common brn mottles					
		17-32	wk AB RC/cl common many distinct fi sp mod						4 332"
		32-61	massive gleyed gbrn sc fri fi sp common mottles	32"+ exp vsp					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____

COMMENTS: _____